

**EVERGREEN**

**LEGEND**

**Residential Wells Results**

- 2009 or Ongoing 2016 Program Sampling Location with Equal to or an Exceedance of the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with a Detection Below the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with Concentrations Below the Limit of Detection (See Notes)
- Declined Sampling

**Expanded Areas**

- Expanded Area 1
- Expanded Area 2
- Expanded Area 3
- Expanded Area 4
- Expanded Area 5
- Expanded Area 6

**Other Symbols**

- Current Investigation Area
- 1- and 2-Mile Radius Interval
- Property Boundary
- Municipal Boundary

**Notes:**

This is an Evergreen sampling location map and will be updated with sampling locations as they are sampled and results are finalized.

Each well sampled is now identified by a Regulatory Location ID so that no personal private information (such as name and address) is provided here to maintain residential confidentiality. Chemours is in the process of notifying drinking-water well owners that have had their drinking-water well sampled of the corresponding Regulatory Location ID. Table 1 provides the results for the samples analyzed for each drinking-water well.

**Limit of Detection as indicated in Table 1.**

Reporting Limit for PFQA, PFOS, and PFNA is 0.002 µg/L.

**Current Criteria Applied:**


- The PFNA maximum contaminant level (MCL) of 13 ng/L (or 0.013 µg/L) adopted by NJDEP on September 4, 2018.
- NJDEP accepted the New Jersey Drinking Water Quality Institute's (DWQI) recommended drinking water standard of 0.013 µg/L for PFOS in June, 2018.
- NJDEP accepted the New Jersey DWQI's recommended drinking water standard of 0.014 µg/L for PFQA on November 1, 2017.

**NJDEP = New Jersey Department of Environmental Protection**

PFQA = Perfluorooctanoic acid  
 PFOS = Perfluorooctanesulfonic acid  
 PFNA = Perfluorononanoic acid

Coordinates for sample locations obtained via GoogleMap, ngsarcels.com, and GIS.

2017 Metro Aerial Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aerogrid, IGN, IGP, swisstopo, and the GIS User Community



**AECOM**

AECOM  
 Suite Building, Suite 300  
 4551 Copley Road  
 Newark, NJ 07103

RESIDENTIAL DRINKING WATER PROGRAM INVESTIGATION WELL SAMPLING LOCATIONS WITH RESULTS AS OF APRIL 16, 2020	
PROJECT NUMBER: 19005	DRAWING NUMBER: 00593797
DESIGNED BY: K. L. DAVIS	DATE: 4/21/2020
DRAWN BY: C. DUFFY	SCALE: 1" = 1,000'
CHECKED BY: N. DEPAISE	SHEET NUMBER: 1