


**EVERGREEN**



**LEGEND**

**Residential Well Results**


- 2009 or Ongoing 2016 Program Sampling Location with Equal to or an Exceedance of the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with a Detection Below the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with Concentrations Below the Limit of Detection (See Notes)

- Current Investigation Area
- Property Boundary
- Municipal Boundary

**Notes:**  
 This is an Evergreen sampling location map and will be updated with sampling locations as they are sampled and results are finalized.  
 Each well sampled is now identified by a Regulatory Location ID so that no private personal information (such as name and address) is provided here to maintain residential confidentiality. Table 1 provides the results for the samples analyzed for each potable well.

**Limit of Detection as indicated in Table 1.**  
 Reporting Limit for PFOA, PFOS, and PFNA is 0.002 micrograms per liter (µg/L).  
 Criteria Applied (µg/L for 2009 and 2016-2023):  
 The NJDEP has a Drinking Water Standard for the following three PFAS:  
 -PFOA is 0.014 µg/L;  
 -PFOS is 0.013 µg/L; and  
 -PFNA is 0.013 µg/L.  
 For wells sampled more than once, the symbol color shown reflects the most recent sampling event results.

NJDEP = New Jersey Department of Environmental Protection  
 PFOA = Perfluorooctanoic acid  
 PFOS = Perfluorooctanesulfonic acid  
 PFNA = Perfluorononanoic acid  
 Coordinates for sample locations obtained via GoogleMap, riparcels.com, NJ-GeoWeb, and GIS.  
 2023 Maxar Vivid Advanced Aerial Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Geomatics, Aerogrid, IGN, IGP, swisstopo, and the GIS User Community



**AECOM**  
 245 Chambers Road  
 Suite 101  
 Newark, DE 19702

|   |                          |
|---|--------------------------|
| RESIDENTIAL POTABLE WELL SAMPLING LOCATIONS WITH RESULTS AS OF JANUARY 26, 2024 |                          |
| ISSUE NUMBER: 23005   | PROJECT NUMBER: 60697560 |
| DESIGNED BY: K. L. DAVIS  | DATE: 1/26/2024          |
| DRAWN BY: C. DUFFY  | SCALE: N/A               |
| APPROVED BY: N. DEPOSE  | PAGE NUMBER: 1           |