


EVERGREEN



LEGEND

Residential Well Results

- 2009 or Ongoing 2016 Program Sampling Location with Equal to or an Exceedance of the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with a Detection Below the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with Concentrations Below the Limit of Detection (See Notes)

- Current Investigation Area
- Expanded Area 1
- Expanded Area 2
- Expanded Area 3
- Expanded Area 4
- Expanded Area 5
- Expanded Area 6
- Expanded Area 7
- Expanded Area 8
- Expanded Area 9
- 1- and 2-Mile Radius Interval
- Property Boundary
- Municipal Boundary


Notes:
 This is an Evergreen sampling location map and will be updated with sampling locations as they are sampled and results are finalized.
 Each well sampled is now identified by a Regulatory Location ID so that no private personal information (such as name and address) is provided here to maintain residential confidentiality. Table 1 provides the results for the samples analyzed for each potable well.

Limit of Detection as Indicated in Table 1.
 Reporting Limit for PFOA, PFOS, and PFNA is 0.002 µg/L.
 Criteria Applied (µg/L) for 2009 and 2016-2022:
 The NJDEP has a Drinking Water Standard for the following three PFAS:
 - PFOA is 0.014 µg/L;
 - PFOS is 0.013 µg/L; and
 - PFNA is 0.013 µg/L.
 For wells sampled more than once, the symbol color shown reflects the most recent sampling event results.

NJDEP = New Jersey Department of Environmental Protection
 PFOA = Perfluorooctanoic acid
 PFOS = Perfluorooctanesulfonic acid
 PFNA = Perfluorononanoic acid

Coordinates for sample locations obtained via GoogleMap, riparcels.com, NJ-Geoweb, and GIS.

2020 Maxar Aerial Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aergrid, IGN, IGP, swisstopo, and the GIS User Community



AECOM
 Suburb Building, Suite 300
 4551 Copleston Road
 Newark, DE 19713

RESIDENTIAL DRINKING WATER
 PROGRAM INVESTIGATION WELL
 SAMPLING LOCATIONS WITH RESULTS
 AS OF AUGUST 10, 2022

CHAMBERS WORKS COMPLEX
 DEERPARKE, NEW JERSEY

DATE: 8/16/2022
 DRAWN BY: K. L. DAVIS
 CHECKED BY: C. DUFFY
 APPROVED BY: N. DEPAISE

1