

EVERGREEN

LEGEND

Residential Wells Results

- 2009 or Ongoing 2016 Program Sampling Location with Equal to or an Exceedance of the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with a Detection Below the Criteria (See Notes)
- 2009 or Ongoing 2016 Program Sampling Location with Concentrations Below the Limit of Detection (See Notes)
- Current Investigation Area

- Expanded Area 1
- Expanded Area 2
- Expanded Area 3
- Expanded Area 4
- Expanded Area 5
- Expanded Area 6
- Expanded Area 7
- Expanded Area

- 1- and 2-Mile Radius Interval
- Property Boundary
- Municipal Boundary

Notes:

This is an Evergreen sampling location map and will be updated with sampling locations as they are sampled and results are finalized.

Each well sampled is now identified by a Regulatory Location ID so that no personal private information (such as name and address) is provided here to maintain residential confidentiality. Chemours is in the process of notifying drinking-water well owners that have had their drinking-water well sampled of the corresponding Regulatory Location ID. Table 1 provides the results for the samples analyzed for each drinking-water well.

Limit of Detection as indicated in Table 1.

Reporting Limit for PFQA, PFOS, and PFNA is 0.002 µg/L.

Current Criteria Applied:


- The PFNA maximum contaminant level (MCL) of 13 ng/L (or 0.013 µg/L) adopted by NJDEP on September 4, 2018.
- NJDEP accepted the New Jersey Drinking Water Quality Institute's (DWQI) recommended drinking water standard of 0.013 µg/L for PFOS in June, 2018.
- NJDEP accepted the New Jersey DWQI's recommended drinking water standard of 0.014 µg/L for PFQA on November 1, 2017.

NJDEP = New Jersey Department of Environmental Protection

PFQA = Perfluorooctanoic acid
 PFOS = Perfluorooctanesulfonic acid
 PFNA = Perfluorononanoic acid

Coordinates for sample locations obtained via GoogleMap, njparcels.com, and GIS.

2017 Metro Aerial Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aergrid, IGN, IGP, swisstopo, and the GIS User Community



AECOM

Suburb Building, Suite 300
 4051 Copleston Road
 Newark, DE 19713

RESIDENTIAL DRINKING WATER PROGRAM INVESTIGATION WELL SAMPLING LOCATIONS WITH RESULTS AS OF DECEMBER 14, 2020	
PROJECT NUMBER: 20005	PROJECT NUMBER: 00593797
DESIGNED BY: K. L. DAVIS	DATE: 12/14/2020
DRAWN BY: C. DUFFY	PROJECT NUMBER:
APPROVED BY: N. DEPASE	1